



**Winston-Salem**

Neighborhood Services  
Department

City of Winston-Salem  
P.O. Box 2511  
Winston-Salem, NC 27102  
336-722-8000  
CityofWS.org

**CODE DEFICIENCIES - EXHIBIT A**

**CASE NO: CE-H-UN-11-06-1386**

**NEIGH. CONSERVATION OFFICER: Shawn Helm - 336-734-1271**

**LOCATION: 211 LAKE VIEW BV, WINSTON-SALEM, NC 27105**

<b>Violation</b>	<b>Status</b>	<b>Date</b>	<b>Comments</b>
<b>REPAIR OR REPLACE SCREENS ON DOORS</b>	<b>UNFIT</b>	<b>06/21/2011</b>	<b>UNDERSIZED AT FRONT</b>
<b>REPAIR OR REPLACE SCREENS ON WINDOWS</b>	<b>UNFIT</b>	<b>06/21/2011</b>	
<b>REPAIR WINDOW BALANCES</b>	<b>UNFIT</b>	<b>06/21/2011</b>	
<b>PROVIDE HEATING FACILITY</b>	<b>UNFIT</b>	<b>06/21/2011</b>	
<b>REPAIR DEFECTIVE SWITCHES AND/OR OUTLETS TO INCLUDE COVERS</b>	<b>UNFIT</b>	<b>06/21/2011</b>	<b>IN BEDROOMS</b>
<b>INSTALL CORRECT SIZE FUSES</b>	<b>UNFIT</b>	<b>06/21/2011</b>	
<b>REPAIR HOLES IN WALLS AND CEILINGS</b>	<b>UNFIT</b>	<b>06/21/2011</b>	<b>IN HALL</b>
<b>REPAIR OR REPLACE ROOF COVERING</b>	<b>UNFIT</b>	<b>06/21/2011</b>	<b>LEAKING INTO LEFT REAR BEDROOM</b>
<b>PROVIDE OPERABLE SMOKE DETECTOR</b>	<b>UNFIT</b>	<b>06/21/2011</b>	<b>INSTALL BATTRIES</b>
<b>HAVE STRUCTURE EXTERMINATED OF INSECTS, RODENTS - OTHER PESTS</b>	<b>UNFIT</b>	<b>06/21/2011</b>	<b>ROACHES</b>