



Community Develop
Department
City of Winston-Salem
P.O. Box 2511

CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2019010494

NEIGH. CONSERVATION OFFICER:

SHAWN HELM - (336)734-1271

LOCATION: 1405 E TWENTY-SECOND ST

<u>VIOL NBR</u>	<u>VIOLATION DESCRIPTION</u> <u>STATUS/ORDINANCE</u>
-----------------	---

913608	PAINT OR TREAT EXTERIOR WOOD WITH PROTECTIVE COATING -
--------	--

MINOR V-10-197(G)(3)

913611	REPAIR DOOR - UNFIT V-10-197(A)(15)
--------	--

913605	REPAIR OR REPLACE DEFECTIVE SIDING - UNFIT V-10-197(G)(3)
--------	--

913606	REMOVE AND REPLACE FIRE DAMAGED PORTION OF STRUCTURE - UNFIT V-4-89(4)
--------	---

913607	EXTERIOR AND INTERIOR FRAMING MUST BE INSPECTED BEFORE COVERING WITH WALL AND CEILING MATERIALS - UNFIT V-4-91
--------	--

913609	REPAIR OR REPLACE FRONT PORCH CEILING - UNFIT V-10-197(G)(7)
--------	---

913610	REPAIR SOFFIT AND/OR FASCIA - UNFIT V-10-197(G)(6)
--------	---