

CODE DEFICIENCIES - EXHIBIT A

APPROVED

CASE NO: 2008080723

NEIGHBORHOOD CONSERVATION OFFICER:

Mike Devlin - (336)734-1258

4842 MONTE VISTA ST

VIOL NBR VIOLATION DESCRIPTION
STATUS/ORDINANCE

619937 PAINT OR TREAT EXTERIOR WOOD WITH PROTECTIVE COATING -
MINOR V-10-197(G)(3)

619943 PAINT WALLS AND CEILINGS -
MINOR V-10-197(G)(4)

619927 PROVIDE DOOR - CLOSET
UNFIT V-10-197(A)(15)

619928 REPAIR LOCKSETS - ALL DOORS EXT.
UNFIT V-10-197(B)(4)

619929 REPLACE BROKEN WINDOW PANES -
UNFIT V-10-197(B)(4)

619930 SECURE COMMODE TO FLOOR -
UNFIT V-10-197(D)(4)

619931 REPAIR LAVATORY AND/OR FIXTURES - REPLACE.
UNFIT V-10-197(D)(10)

619932 REPAIR TUB FIXTURES -
UNFIT V-10-197(D)(10)

619933 REPAIR DEFECTIVE SWITCHES AND/OR OUTLETS TO INCLUDE COVERS -
UNFIT V-10-197(F)(1)

619934 REPAIR DEFECTIVE LIGHT FIXTURES -
UNFIT V-10-197(F)(1)

619935 REPAIR OR REPLACE LOOSE FLOOR COVERING I - THOUGHTOUT HOUSE.
UNFIT V-10-197(G)(2)

619936 PROVIDE OPERABLE SMOKE DETECTOR -
UNFIT V-10-197(L)(1)

619939 REPAIR HOLES IN WALLS AND CEILINGS -
UNFIT V-10-197(G)(4)

619940 REPLACE LOOSE WALL AND CEILING MATERIALS IN -
UNFIT V-10-197(G)(4)

619944 REPAIR, REPLACE OR REMOVE GUTTERS AND DOWNSPOUTS -
UNFIT V-10-197(G)(6)

619945 REPAIR OR REPLACE ROOF COVERING -
UNFIT V-10-197(G)(6)

619946 REPAIR OR REPLACE STEPS AT INTERIOR -
UNFIT V-10-197(G)(8)

APPROVED