

CASE NO: CE-H-UN-16-04-1767

1818 N DUNLEITH AV APT. A

VIOL NBR VIOLATION DESCRIPTION
STATUS/ORDINANCE

851731 REPLACE LOOSE WALL AND CEILING MATERIALS -
MINOR V-10-197(G)(4)

851726 REPAIR DOOR - CASING DESTROYED
UNFIT V-10-197(A)(15)

851727 REPAIR DEFECTIVE SWITCHES AND/OR OUTLETS TO INCLUDE COVERS -
UNFIT V-10-197(F)(1)

851728 REPLACE BROKEN WINDOW PANES -
UNFIT V-10-197(B)(4)

851730 REPAIR HOLES IN WALLS AND CEILINGS -
UNFIT V-10-197(G)(4)

851732 REPAIR FURNACE - PLATE MISSING
UNFIT V-10-197(E)(2)

851733 REPAIR OR REPLACE LOOSE FLOOR COVERING -
UNFIT V-10-197(G)(2)

851734 REPAIR LOCKSETS - ALL DOORS
UNFIT V-10-197(B)(4)

851736 MAINTAIN FLOORS, WALLS - FIXTURES IN CLEAN AND SANITARY CONDITION -
UNFIT V-10-197(H)(4)

CASE NO: CE-H-HZ-16-04-1771

1818 N DUNLEITH AV APT. B

VIOL NBR VIOLATION DESCRIPTION
STATUS/ORDINANCE

851742 REPLACE LOOSE WALL AND CEILING MATERIALS -
MINOR V-10-197(G)(4)

851744 MAINTAIN FLOORS, WALLS - FIXTURES IN CLEAN AND SANITARY CONDITION - MILDEW ON
WALLS
MINOR V-10-197(H)(4)

851747 REPAIR OR REPLACE LOOSE FLOOR COVERING -
MINOR V-10-197(G)(2)

851749 REPAIR KITCHEN CABINETS -
MINOR V-10-197(A)(16)

851738 REPAIR OR REPLACE SCREENS ON WINDOWS -
UNFIT V-10-197(B)(3)

851739 REPAIR HOLES IN WALLS AND CEILINGS -
UNFIT V-10-197(G)(4)

851741 REPAIR DEFECTIVE SWITCHES AND/OR OUTLETS TO INCLUDE COVERS -
UNFIT V-10-197(F)(1)

851743 REPAIR FURNACE - PANEL MISSING
UNFIT V-10-197(E)(2)

851746 REPAIR COMMODE -
UNFIT V-10-197(D)(2)

851748 REPAIR KITCHEN SINK, FIXTURES AND/OR DRAIN -
UNFIT V-10-197(D)(10)

851750 REPAIR LOCKSETS -
UNFIT V-10-197(B)(4)

851751 REPLACE BROKEN WINDOW PANES -
UNFIT V-10-197(B)(4)

851752 OTHER - EXPOSED WIRING
UNFIT V-10-197

851753 REPAIR COMMODE -
UNFIT V-10-197(D)(2)

851740 PROVIDE ADEQUATE SERVICE EQUIPMENT AND LIGHTING PANEL -
UNFIT HAZARDOUS V-10-197(F)(10)

CASE NO: CE-H-UN-16-04-1740

1818 DUNLEITH AVE. APT. C

VIOL NBR VIOLATION DESCRIPTION

STATUS/ORDINANCE

851687 OTHER - STOVE HAS NO KNOBS
MINOR V-10-197

851693 MAINTAIN FLOORS, WALLS - FIXTURES IN CLEAN AND SANITARY CONDITION - GRAFITTI
MINOR V-10-197(H)(4)

851682 REPAIR DOOR -
UNFIT V-10-197(A)(15)

851684 REPAIR LOCKSETS - EXT DOORS
UNFIT V-10-197(B)(4)

851685 REPAIR HOLES IN WALLS AND CEILINGS -
UNFIT V-10-197(G)(4)

851689 REPLACE BROKEN WINDOW PANES -
UNFIT V-10-197(B)(4)

851690 REPAIR KITCHEN SINK, FIXTURES AND/OR DRAIN -
UNFIT V-10-197(D)(10)

851691 PROVIDE PROPER DISCHARGE TUBE - HOT WATER HEATER -
UNFIT V-10-193(7)

851692 PROVIDE OPERABLE SMOKE DETECTOR -
UNFIT V-10-197(L)(1)

CASE NO: CE-H-UN-16-04-1773
1818 N DUNLEITH AV APT. D

VIOL NBR VIOLATION DESCRIPTION
STATUS/ORDINANCE

851754 PROVIDE DOOR -
UNFIT V-10-197(A)(15)

851755 REPAIR LOCKSETS -
UNFIT V-10-197(B)(4)

851756 REPAIR KITCHEN SINK, FIXTURES AND/OR DRAIN -
UNFIT V-10-197(D)(10)

851757 PROVIDE PROPER DISCHARGE TUBE - HOT WATER HEATER -
UNFIT V-10-193(7)

851758 REPAIR COMMODE -
UNFIT V-10-197(D)(2)

851759 PROVIDE OPERABLE SMOKE DETECTOR -
UNFIT V-10-197(L)(1)

851760 OTHER - EPOSED WIRING
UNFIT V-10-197