



Community Development
Department

City of Winston-Salem
P.O. Box 2511
Winston-Salem, NC 27102
CityLink 311 (336.727.8000)
Fax 336.727.2878
www.cityofws.org

CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2017040178

NEIGH. CONSERVATION OFFICER: QUIVETTE POWELL - (336)734-1277

LOCATION: 1629 E FOURTEENTH ST

VIOL NBR VIOLATION DESCRIPTION
STATUS/ORDINANCE

874822 PAINT WALLS AND CEILINGS - IN THE HALLWAY
MINOR V-10-197(G)(4)

874818 REPAIR OR REPLACE DEFECTIVE SIDING - ON THE FRONT OF THE HOUSE
MINOR V-10-197(G)(3)

874819 HAVE STRUCTURE EXTERMINATED OF INSECTS, RODENTS - OTHER PESTS -
MINOR V-10-197

874817 REPAIR DOOR - REPAIR BEDROOM DOOR AND BACK DOOR
UNFIT V-10-197(A)(15)

874820 REPAIR FOUNDATION VENTS - REPLACE VENT ON THE SIDE OF THE HOUSE
UNFIT V-10-197(H)(6)(B)

874816 PROVIDE OPERABLE SMOKE DETECTOR - SMOKE DETECTORS NEEDS TO BE
IN ALL BEDROOMS
UNFIT V-10-197(L)(1)