

CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2012101750

NEIGHBORHOOD CONSERVATION OFFICER:
DARYL GREEN - (336)734-1276

912 GOLDFLOSS ST

VIOL NBR VIOLATION DESCRIPTION
 STATUS/ORDINANCE

753201 OTHER - SENT LETTER TO SECURE
MINORV-10-197

753455 REPAIR HOLES IN WALLS AND CEILINGS - IN REAR ROOM OFF KITCHEN
MINORV-10-197(G)(4)

753199 HAVE STRUCTURE EXTERMINATED OF INSECTS, RODENTS - OTHER PESTS -
UNFIT V-10-197

753200 MAINTAIN FLOORS, WALLS - FIXTURES IN CLEAN AND SANITARY CONDITION -
UNFIT V-10-197(H)(4)

753452 REPLACE BROKEN WINDOW PANES - ON FRONT
UNFIT V-10-197(B)(4)

753453 REPAIR OR REPLACE LOOSE FLOOR COVERING - REAR ROOM OFF KITCHEN
UNFIT V-10-197(G)(2)

753454 REPAIR DOOR - IN REAR
UNFIT V-10-197(A)(15)

753456 REPAIR COMMUNE - REPAIR COMMUNE TOP
UNFIT V-10-197(D)(2)

753457 PROVIDE DOOR - KNOB ON CLOSET DOOR
UNFIT V-10-197(A)(15)

753458 PROVIDE OPERABLE SMOKE DETECTOR - ALL BEDROOMS
UNFIT V-10-197(L)(1)

753459 REPAIR FOUNDATION - ON SIDE
UNFIT V-10-197(G)(1)