



CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2011071831

NEIGH. CONSERVATION OFFICER: TONY WRIGHT - (336)734-1267

LOCATION: 4710 OLD RURAL HALL RD

VIOL NBR VIOLATION DESCRIPTION
STATUS/ORDINANCE

713841 REPAIR OR REPLACE LOOSE FLOOR COVERING - THOUGHOUT
MINORV-10-197(G)(2)

713844 REPAIR OR REPLACE DEFECTIVE SIDING -
MINORV-10-197(G)(3)

713847 PAINT OR TREAT EXTERIOR WOOD WITH PROTECTIVE COATING -
MINORV-10-197(G)(3)

713834 REPAIR FOUNDATION -
UNFIT V-10-197(G)(1)

713835 REPAIR CRAWL SPACE DOOR -
UNFIT V-10-197(G)(1)

713836 REPAIR DOOR -
UNFIT V-10-197(A)(15)

713837 REPAIR PLUMBING LEAK UNDER STRUCTURE -
UNFIT V-10-197(D)(15)

713838 REPAIR HOLES IN WALLS AND CEILINGS - THOUGHOUT
UNFIT V-10-197(G)(4)

713839 REPAIR KITCHEN CABINETS -
UNFIT V-10-197(A)(16)

713840 REPAIR DEFECTIVE LIGHT FIXTURES - 10
UNFIT V-10-197(F)(1)

713842 REPAIR OR REPLACE WATER HEATER -
UNFIT V-10-197(D)(8)

713843 PROVIDE PROPER DISCHARGE TUBE - HOT WATER HEATER -
UNFIT V-10-193(7)

713845 OTHER - REPAIR SILL PLATE
UNFIT V-10-197

713846 REPAIR OR REPLACE SCREENS ON WINDOWS -
UNFIT V-10-197(B)(3)

Community Development
Department

City of Winston-Salem
P.O. Box 2511
Winston-Salem, NC 27102
CityLink 311 (336.727.8000)
Fax 336.727.2878
www.cityofws.org