

CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2016020845

NEIGHBORHOOD CONSERVATION OFFICER:
SHAWN HELM - (336)734-1271

2700 PATRIA ST

VIOL NBR VIOLATION DESCRIPTION
 STATUS/ORDINANCE

846503 PAINT OR TREAT EXTERIOR WOOD WITH PROTECTIVE COATING -
MINOR V-10-197(G)(3)

846505 OTHER - REPAIR SLOW DRAIN IN BATH SINK
MINOR V-10-197

846509 REPAIR CRAWL SPACE DOOR -
MINOR V-10-197(G)(1)

846510 REPAIR OR REPLACE DEFECTIVE SIDING - BACK
MINOR V-10-197(G)(3)

846511 OTHER - REPAIR RETAINING WALL (LEFT SIDE IN FRONT)
MINOR V-10-197

846500 REPAIR SEWER LINE - FRONT YARD
UNFIT V-10-197(D)(15)

846504 REPAIR SOFFIT AND/OR FACIA - FRONT
UNFIT V-10-197(G)(6)

846506 HAVE STRUCTURE EXTERMINATED OF INSECTS, RODENTS - OTHER PESTS -
UNFIT V-10-197

846507 PROVIDE OPERABLE SMOKE DETECTOR -
UNFIT V-10-197(L)(1)

846508 INSTALL PROPER SIZE FUSES -
UNFIT V-10-197(F)(8)