



CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2019110457

NEIGH. CONSERVATION OFFICER: TONY WRIGHT - (336)734-1267

LOCATION: 3460 NEW WALKERTOWN RD

<u>VIOL NBR</u>	<u>VIOLATION DESCRIPTION</u>	<u>STATUS/ORDINANCE</u>
-----------------	------------------------------	-------------------------

930227	REPAIR SOFFIT AND/OR FASCIA	-
	UNFIT	V-10-197(G)(6)

930228	REPLACE BROKEN WINDOW PANES	-
	UNFIT	V-10-197(B)(4)

930229	REMOVE AND REPLACE FIRE DAMAGED PORTION OF STRUCTURE	-
	UNFIT	V-4-89(4)

930230	PROVIDE REQUIRED FIRE-RESISTANCE PROTECTION TO PARTY WALLS AND CEILINGS	-
	UNFIT	702.3/SBC

930231	EXTERIOR AND INTERIOR FRAMING MUST BE INSPECTED BEFORE COVERING WITH WALL AND CEILING MATERIALS	-
	UNFIT	V-4-91

930232	PROVIDE REQUIRED FIRE-RESISTANCE PROTECTION TO PARTY WALLS AND CEILINGS	-
	UNFIT	702.3/SBC

Community Development
Department

City of Winston-Salem
P.O. Box 2511
Winston-Salem, NC 27102
CityLink 311 (336.727.8000)
Fax 336.727.2878
www.cityofws.org