



# W-3538 Wells Fargo Silas Data Center - Fuel System Project (Site Plan Amendment)

Bryce A. Stuart Municipal Building 100 East First Street, Suite 225 Winston-Salem, NC 27101 Fax: 336-748-3163

City of W-S Planning

Travis Pruitt
Pruitt & Associates, Inc.
4317 Park Drive
Suite 400
Norcross, GA 30093

Phone: 336-747-7040

Project Name: W-3538 Wells Fargo Silas Data Center - Fuel

System Project (Site Plan Amendment) Jurisdiction: City of Winston-Salem

ProjectID: 781189

Wednesday, June 22, 2022

The comments listed below reflect remaining issues that must be addressed before your request can proceed to the Planning Board. All outstanding issues included in this list must be satisfactorily addressed on the revised site plan and re-submitted back to Planning staff no later than 5:00pm on the Thursday two weeks before (14 days prior to) the Planning Board meeting.

Open Issues: 11

**Engineering** 

**General Issues** 

9. General comments

Matthew Gantt

336-727-8000

6/21/22 8:00 AM 01.13) Application for Site Plan Amendment -

City of Winston-Salem 1. A driveway permit request was submitted for this facility on 12/10/21. This application was declined on 12/20/21 for an incomplete driveway permit application. This plan included a driveway connection to Sunnynoll Court, which has not been shown matthewg@cityofws.org on the 6/14/22 plan.

### **Erosion Control**

#### 10. Erosion Control Permit Revisions Required

Matthew Osborne

336-747-7453

6/21/22 11:33 AM

01.13) Application for Site Plan Amendment -

Plan, a revised plan submittal will be required for Grading Permit # EN2000130. Please submit a revised Erosion Control Plan for review, along with a new Financial Responsibility/Ownership Form showing the matthewo@cityofws.org additional disturbed area calculations.

[Ver. 2] [Edited By Matthew Osborne]

## Fire/Life Safety

#### 7. Notes

# Winston-Salem Fire Department

Cory Lambert 336-747-7359

# coryml@cityofwsfire.org

6/17/22 11:05 AM 01.13) Application for Site Plan Amendment -

Ensure fire apparatus access roads are provided, designed, built and maintained in compliance with fire code requirements. These requirements include but are not limited to the following items:

- Design, construction and maintenance of fire apparatus access roads to carry an imposed load of not less than 75,000 pounds;
- Clear width requirements of not less than 20 feet for two-way traffic;
- Clear height requirements of not less than 13 feet, 6 inches;
- Design, construction and maintenance of approved turnaround designs for fire apparatus access roads when the dead-end length of the required access road is more than 150 feet.
- Gates may not obstruct fire apparatus access roads unless approved by the Winston-Salem Fire Department; approval requires compliance with all applicable fire code requirements.

[Ver. 2] [Edited By Cory Lambert]

### MapForsyth Addressing Team

## 8. Addressing & Street Naming

Forsyth County
Government

Address assign at permitting.

Gloria Alford 3367032337

alfordgd@forsyth.cc

6/20/22 11:14 AM

01.13) Application for

Site Plan Amendment -

2

#### **NCDOT**

#### **General Issues**

#### 5. NCDOT Comments

NCDOT Division 9

Victoria Kildea

336-747-7900

vrkildea@ncdot.gov

6/14/22 2:52 PM

01.13) Application for

Site Plan Amendment -

2

### **Planning**

#### **General Issues**

#### 1. COUNCIL MEMBER CONTACT

City of Winston-Salem

Marc Allred 336-727-8000

marca@cityofws.org 5/31/22 2:05 PM

Pre-Submittal Workflow

- 1

Pruitt & Associates, Inc. Thanks. Understood.

Travis Pruitt

7704167511

eplan@travispruitt.com

6/13/22 5:36 PM

Pre-Submittal Workflow

- 1

#### 2. Site Plan Amendment

City of Winston-Salem Will require a Site Plan Amendment for the proposed use; Neighborhood outreach will

Marc Allred

336-727-8000

marca@cityofws.org

5/31/22 2:05 PM

Pre-Submittal Workflow

- 1

• The proposed fence needs to be outside of the right of way.

Please ensure that you have contacted the appropriate Council Member and/or

the Community Assistance Liaison for their office prior to the Planning Board

Hearing. Be advised that Council Members may want to participate in any

community outreach efforts . Information for each Council Member can be

found on their website here: https://www.cityofws.org/564/City-Council

be required with a summary required 8 days prior to Planning Board hearing.

Pruitt & Associates, Inc. Thanks. Understood.

Travis Pruitt 7704167511

eplan@travispruitt.com

6/13/22 5:36 PM

Pre-Submittal Workflow

- 1

#### 3. Historic Resources

City of Winston-Salem No comments

Heather Bratland 336-727-8000

heatherb@cityofws.org

6/14/22 8:28 AM

01.13) Application for

Site Plan Amendment -

2

# 6. Environmental Features/Greenways

City of Winston-Salem No comments.

Elizabeth Colyer 336-747-7427

elizabethrc@cityofws.org

6/16/22 11:00 AM

01.13) Application for

Site Plan Amendment - 2

#### 11. CAC

City of Winston-Salem No comment.

Amy Crum

336-747-7051

amyc@cityofws.org

6/21/22 4:55 PM

01.13) Application for

Site Plan Amendment -

### Utilities

#### 4. General Comments

Robert Wall

336-727-8000

robertw@cityofws.org 6/15/22 9:33 AM

Site Plan Amendment -

City of Winston-Salem Submit water extension plans to Utilities Plan Review, in IDT, for permitting/approval. If the wall is going to be constructed out of brick and block, as shown in the one rendering the wall must be a minimum of 10' off of the water line along Silas Creek Parkway. If the fence is to be constructed out of the fence style, as in rendering it will need to be a minimum of 5' off of the water line Silas Creek Parkway.

01.13) Application for [Ver. 4] [Edited By Robert Wall]