



W-3539 Hanes Mill Road MSE Wall (Site Plan Amendment)

Bryce A. Stuart Municipal Building 100 East First Street, Suite 225 Winston-Salem, NC 27101 Fax: 336-748-3163

City of W-S Planning

Emily Tucker HDR Engineering 440 South Church Street charlotte, NC 28202

Phone: 336-747-7040

Project Name: W-3539 Hanes Mill Road MSE Wall (Site Plan

Amendment)

Jurisdiction: City of Winston-Salem

ProjectID: 800764

Wednesday, July 20, 2022

The comments listed below reflect remaining issues that must be addressed before your request can proceed to the Planning Board. All outstanding issues included in this list must be satisfactorily addressed on the revised site plan and re-submitted back to Planning staff no later than 5:00pm on the Thursday two weeks before (14 days prior to) the Planning Board meeting.

Open Issues: 10

Engineering

11. General comments

Matthew Gantt

City of Winston-Salem 1. Access to the active landfill is provided through the existing facility. Therefore, no City driveway permit is required.

336-727-8000 matthewg@cityofws.org

7/7/22 7:44 AM 01.13) Application for Site Plan Amendment -

Erosion Control

10. Erosion Control Plan Review to NCDEQ - DEMLR

City of Winston-Salem Matthew Osborne 336-747-7453

If this project will use any public funds, then Erosion Control Plan approval will need to be completed through NCDEQ - DEMLR. The contact for NCDEQ - DEMLR at the Winston-Salem Regional Office is Tamera Eplin (336-776-9800).

matthewo@cityofws.org

7/6/22 12:47 PM 01.13) Application for Site Plan Amendment -

Fire/Life Safety

General Issues

15. Notes

City of Winston-Salem (Fire) Raven Byrd 336-734-2492 ravenb@cityofws.org 7/14/22 2:04 PM 01.13) Application for

2

Indicate locations of fire hydrants (existing and proposed) to demonstrate compliance with fire code requirements and City development standards.

For those buildings on this site that are equipped with sprinkler or standpipe systems, indicate the location of each FDC, ensuring no FDC is more than 100 feet from a fire hydrant.

Site Plan Amendment - Ensure fire apparatus access roads are provided, designed, built and maintained in compliance with fire code requirements. These requirements include but are not limited to the following items:

- Design, construction and maintenance of fire apparatus access roads to carry an imposed load of not less than 75,000 pounds;
- Clear width requirements of not less than 20 feet for two-way traffic;
- Clear height requirements of not less than 13 feet, 6 inches;
- Design, construction and maintenance of approved turnaround designs for fire apparatus access roads when the dead-end length of the required access road is more than 150 feet.
- Gates may not obstruct fire apparatus access roads unless approved by the Winston-Salem Fire Department; approval requires compliance with all applicable fire code requirements.

As part of your construction plan submittal, include the calculations for needed fire flow for this project and indicate the approved method of calculation in use. Buildings that are equipped with sprinkler systems throughout are exempt from this requirement. Refer to Section 507 of the 2018 NC Fire Code for further information. Approved calculation methods include the following options:

- Appendix B of the 2018 NC Fire Code; or
- the ISO Fire Suppression Rating Schedule (as described in https://www.isomitigation.com/siteassets/downloads/guidedeterminerequiredfireflow.pdf).

Emergency responder radio coverage shall meet the requirements of Section 510 of the 2018 NC Fire Code for this project. Consider how these requirements, including any systems necessary to bring radio coverage into compliance with this section, may impact your plans.

MapForsyth Addressing Team

16. Addressing & Street Naming

Forsyth County Government

Address issue at permitting. [Ver. 2] [Edited By Gloria Alford]

Gloria Alford 3367032337

alfordgd@forsyth.cc

7/20/22 9:37 AM

01.13) Application for

Site Plan Amendment -

Planning

General Issues

7. COUNCIL MEMBER CONTACT

City of Winston-Salem Marc Allred 336-727-8000

marca@cityofws.org 6/28/22 1:47 PM

Pre-Submittal Workflow -

Please ensure that you have contacted the appropriate Council Member and/or the Community Assistance Liaison for their office prior to the Planning Board Hearing. Be advised that Council Members may want to participate in any community outreach efforts . Information for each Council Member can be found on their website here: https://www.cityofws.org/564/City-Council

HDR Engineering

Emily Tucker 7043386700

emily.tucker@hdrinc.com 7/5/22 10:49 AM

Pre-Submittal Workflow -

1

The appropriate Council Member and/or the Community Assistance Liaison, including Mayor Pro Tempore Denise Adams of the North Ward and Council Member Barbara Burke of the Northeast Ward, are being made aware of this project as well as the Neighborhood Meeting.

[Ver. 2] [Edited By Emily Tucker]

12. Environmental Features/Greenways

City of Winston-Salem Elizabeth Colyer

336-747-7427

7/8/22 9:49 AM 01.13) Application for Site Plan Amendment - 2

A greenway is proposed along Grassy Creek in the Greenway Plan Update. A 40 ft. greenway easement is requested along the eastern side of the creek. The easement must begin outside of the undisturbed portion of the required stream buffer per the elizabethrc@cityofws.org Stormwater Management Ordinance, if no Stormwater provisions apply, then the easement shall begin 10 feet from top of bank.

> The Unified Development Ordinances require the easement be recorded through a plat.

13. Historic Resources

City of Winston-Salem No comments

Heather Bratland 336-727-8000

heatherb@cityofws.org

7/11/22 8:25 AM

01.13) Application for

Site Plan Amendment -

17. Height of Wall

City of Winston-Salem What is the average height of MSE wall?

Marc Allred 336-727-8000

marca@cityofws.org

7/19/22 3:01 PM

01.13) Application for

Site Plan Amendment -

18. Timeline

City of Winston-Salem - Corrections to site plan is due July 28.

Marc Allred 336-727-8000 - Community Outreach is due August 3.

Carolina, at 4:30 P.M.

marca@cityofws.org 7/19/22 3:02 PM

- Planning Board is August 11 at Arnold G. King Public Meeting Room on the fifth floor of the Bryce Stuart Municipal Building, 100 East First Street, Winston-Salem, North

01.13) Application for Site Plan Amendment -

Stormwater

9. Exempt from Stormwater Management

Joe Fogarty 336-747-6961

josephf@cityofws.org

7/6/22 11:59 AM 01.13) Application for Site Plan Amendment -

City of Winston-Salem This development will be exempt from having to do any Stormwater management under the City of Winston-Salem's Post Construction Stormwater Management ordinance as impervious area additions, if any, are minimal and therefore the development thresholds that require management for either quality or quantity will not be exceeded.