

CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2016080495

NEIGHBORHOOD CONSERVATION OFFICER:
OLA BROWN - (336)734-1260

111 METHODIST DR ACC BLDG

<u>VIOL NBR</u>	<u>VIOLATION DESCRIPTION</u>	<u>STATUS/ORDINANCE</u>
-----------------	------------------------------	-------------------------

862112	THE REPAIR OF THE STRUCTURE WILL EXCEED SIXTY-FIVE PERCENT (65%) OF THE VALUE - DEMO V-97-(B)(2)	
--------	---	--

862114	REPAIR OR REPLACE DEFECTIVE SIDING - UNFIT V-10-197(G)(3)	
--------	--	--

862115	REPAIR OR REPLACE ROOF COVERING - UNFIT V-10-197(G)(6)	
--------	---	--

862113	REPAIR OR REMOVE ACCESSORY BUILDING - UNFIT V-10-197(G)(9)	
--------	---	--

862116	REPAIR SOFFIT AND/OR FACIA - UNFIT V-10-197(G)(6)	
--------	--	--

862117	REPLACE DEFECTIVE RAFTERS - UNFIT V-10-197(G)(6)	
--------	---	--

862118	REPLACE DEFECTIVE SHEATHING - UNFIT V-10-197(G)(6)	
--------	---	--

862119	REPAIR FOUNDATION - UNFIT V-10-197(G)(1)	
--------	---	--