

CODE DEFICIENCIES - EXHIBIT A

CASE NO: 2015100153

NEIGHBORHOOD CONSERVATION OFFICER:
SHAWN HELM - (336)734-1271

4304 S MAIN ST

<u>VIOL NBR</u>	<u>VIOLATION DESCRIPTION</u>	<u>STATUS/ORDINANCE</u>
-----------------	------------------------------	-------------------------

839301	PAINT OR TREAT EXTERIOR WOOD WITH PROTECTIVE COATING -	MINOR V-10-197(G)(3)
--------	--	----------------------

839305	PAINT WALLS AND CEILINGS - THROUGHOUT HOUSE	MINOR V-10-197(G)(4)
--------	---	----------------------

839309	OTHER - REMOVE MOLD (BATHROOM AND HALLWAY)	MINOR V-10-197
--------	--	----------------

839299	REPAIR OR REPLACE SCREENS ON WINDOWS -	UNFIT V-10-197(B)(3)
--------	--	----------------------

839302	REPLACE LOOSE WALL AND CEILING MATERIALS - THROUGHOUT HOUSE	UNFIT V-10-197(G)(4)
--------	---	----------------------

839303	REPAIR HOLES IN WALLS AND CEILINGS - UTILITY ROOM WALL	UNFIT V-10-197(G)(4)
--------	--	----------------------

839304	REPAIR DEFECTIVE FLOORING - UTILITY ROOM	UNFIT V-10-197(G)(2)
--------	--	----------------------

839306	REPAIR COMMODE - MISSING	UNFIT V-10-197(D)(2)
--------	--------------------------	----------------------

839307	REPAIR OR REPLACE HANDRAIL AT INTERIOR STEPS - ATTIC	UNFIT V-10-197(G)(8)
--------	--	----------------------

839308	REPAIR FOUNDATION - BACK AND LEFT SIDE	UNFIT V-10-197(G)(1)
--------	--	----------------------

839310	REPAIR HOLES IN WALLS AND CEILINGS - HALLWAY	UNFIT V-10-197(G)(4)
--------	--	----------------------

839311	PROVIDE R-19 CEILING INSULATION -	UNFIT V-10-197(I)
--------	-----------------------------------	-------------------